



## Risk assessment

Date

Description of works	Risk of	Risk to	Control Measures to PREVENT ACCIDENTS	LR MR HR
HAZARD				
Moving Vehicles	Trapping	Operatives	Sign in at Gate house if applicable and let them know exactly which area work is being done. Ensure that operatives ARE wearing high visibility clothing No wandering around site Always work in designated safe zone. This will be instructed on site by Shay O'Toole jetting supervisor and company Director	LR MR HR
Power tools Use of Mini 700 machine maybe required on this site	Electrocution	Operatives	Ensure that ONLY competent operatives may use the power tools. ONLY use 110v Drills or other power tools on site. Only use power tools in a safe manor, anybody found using power tools in an unsafe manor will be dismissed immediately. Only use power tools in the dry. Ensure that any power tool that is required for use is to be thoroughly checked out before hand and is PAT tested <b>NOT APPLICABLE ON THIS JOB</b>	N/A
Manual handling	Pains and strains	Operatives	All operatives are to be trained in the correct procedures of manual handling techniques. Wherever possible mechanical lifting devices are to be used.	LR
Slips, Trips, And Falls	Breaks, cuts, and bruises,	Operatives	Area of required works is to be taped off or barriers put in place where possible. Good work area housekeeping. Access to work space, by clear and clutter free walk way.	LR
Hand Tools	Cuts, bruises	Operatives	Always use the correct tool for the job. Always have trained operatives using the tools required for the job. Required P.P.E should always be warned.	LR MR HR
Confined space entry	Trapping, slipping, gasses	Operatives public	ONLY persons who are trained in confined spaces are allowed to lift chambers/ manhole covers ALWAYS use gas detectors before considering entry into manhole ONLY persons trained in confined spaces may enter manholes AND MUST always use a buddy system ENSURE winch is in place before entry and harness is fitted to engineer and winch AT ALL TIMES while confined space work is carried out NEVER open a manhole without sealing off at least 3x3mtr square around manhole NEVER LEAVE a manhole open or unguarded	N/A No entry to be made
Work at Height	Breaks, Cuts Bruises	Operatives	<b>NO WORKING OFF STEP LADDERS AT ANY STAGE OR HEIGHT; SCAFFOLD MUST ALWAYS BE USED IF WORKING OFF THE FLOOR. SCAFFOLD WILL BE SUPPLIED, ERECTED, INSPECTED, AND SCAFFTAGGED BEFORE USE,</b>	LR